



# AHMEDABAD MUNICIPAL CORPORATION

## FIRE AND EMERGENCY SERVICES DEPARTMENT

DANAPITHI FIRE STATION (HEADQUARTERS), NR. AMC OFFICE, DANAPITHI, AHMEDABAD

NOC Number: NOC119305062021

Category: School

NOC Issue Date: 22/04/2021

### NO OBJECTION CERTIFICATE

This is to certify that management of M/s AAVISHKAR SCHOOL located at AHED OF OGNAJ CIRCLE, S.P. RING ROAD AHMEDABAD has installed necessary Fire Protection Equipments mentioned below.

#### Hydrant System With

- |                               |              |
|-------------------------------|--------------|
| • Main Pump                   | - ( 1 Nos.)  |
| • Hose Box with Hose          | - ( 9 Nos.)  |
| • Hydrant Point / Valve       | - ( 11 Nos.) |
| • Fire Bridge Inlet (2/4 Way) | - ( 1 Nos.)  |
| • Hose Reel                   | - ( 9 Nos.)  |
| • Short Branch                | - ( 9 Nos.)  |
| • Manual Call Point           | - ( 9 Nos.)  |
| • Fire Alarm System Installed | Yes          |

#### Fire Extinguishers

- |                             |              |
|-----------------------------|--------------|
| • 6 Kg. Capacity ABC Type   | - ( 7 Nos.)  |
| • 4.5 Kg. Capacity Co2 Type | -- ( 9 Nos.) |
| • Modular Type              | - ( 6 Nos.)  |

All the Fire Protection Equipments installed shall be maintained in working order throughout the validity period of this certificate.

This Certificate is valid for ONE YEAR from the date of issue.



(Rajesh Bhatt)

Chief Fire Officer (I/c)

Scanned By Scanner Go  
Ahmedabad Municipal Corporation