



afes@ahmedabadcity.gov.in



**FORM B 13.3**  
**FIRE SAFETY CERTIFICATE RENEWAL (FSCR)**  
(See Rule 25)

**Fire Safety Certificate Approval (FSCA) No.** FSCA/O/CFOAMC/2021/00012941  
**FSC Safety Certificate Renewal (FSCR) No.** FSCA/O/CFOAMC/2021/00012941/R1

**Date:** 12/05/2026

**Building Occupancy/Category:** Educational (non-residential)

To,

Jignesh Popat  
AAVISHKAR SCHOOL AHED OF OGNAJ CIRCLE,S.P.RING ROAD GOTA AHMEDABAD Ahmedabad MC 380060  
**Fire Region:** Ahmedabad MC  
**Mobile No:** 9978999195 **Email ID:** jigneshpopat.jp@gmail.com

We have received Application No. **2026/00184923** dated 29/04/2026 for **Fire Safety Certificate Renewal (FSCR)** - New Building(FSCR)/Existing Building (FSCRe) for the building/premise **AAVISHKAR SCHOOL (name of the Building/Project)**, as per below mentioned details:

- 1. TP Number:**
- 2. FP Number:**
- 3. Survey Number:**
- 4. Village Name:** AHMEDABAD
- 5. Name of Block(s):** 1

The building/premise was inspected on **12/05/2026** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

- Emergency drill was carried out on **08/05/2026 12:24:11 PM**
- Six monthly inspection was done on **08/05/2026 12:33:45 PM**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **05/06/2028** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated: **12/05/2026 7:22:15 PM**



**Digitally Verified**

Digitally verified by: Brijesh Parshottambhai Gajera  
Fire Safety Officer - Advance (FSO-A)  
2021/001129  
Reviewed by : CFO Ahmedabad MC  
Date: 12/05/2026  
Time: 07:43 PM



FSCA/O/CFOAMC/2021/00012941/R1

*This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetycop.in](http://www.gujfiresafetycop.in).*

*Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.*